

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No.

0370-CPR-3261

In compliance with Regulation (EU) No.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS:

VOICE ALARM CONTROL AND INDICATING EQUIPMENT
 MODEL: NEO 8060 + (NEO 8250E, NEO 4250E, NEO 4500E, NEO 4500LE)

Placed on the market under the name of:

LDA AUDIO VIDEO PROFESIONAL, S.L.

C/ SEVERO OCHOA, 31 – PARQUE TECNOLÓGICO ANDALUCÍA 25590 MÁLAGA (SPAIN)

And produced in the manufacturing plant:

C/ SEVERO OCHOA, 31 – PARQUE TECNOLÓGICO ANDALUCÍA 25590 MÁLAGA (SPAIN)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-16:2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 1st March 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 4th November 2022.

The monitoring assessment will be done before 31st January 2024

Bellaterra, 4th November 2022

Applus

GAI Technological Center, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex, whose number coincides with the number of certificate

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility







Technical Annex Ed. 5 06/05/2022

0370-CPR-3261

Annexes according to EN 54-16:2008

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 16: VOICE ALARM CONTROL AND INDICATING **EQUIPMENT**

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
General Requirements	4.	PASS
General Requirements For Indications	5.	PASS
The Quiescent Condition	6.	PASS
Reception and processing of fire signals	7.1	PASS
Indication of the voice alarm condition	7.2	PASS
Audible warning (option with requirements)	7.3	PASS
Delays to entering the voice alarm condition (option with requirements)	7.4	NPD
Phased evacuation (option with requirements)	7.5	PASS
Silencing of the voice alarm condition	7.6	PASS
Reset of the voice alarm condition	7.7	PASS
Output to fire alarm devices (option with requirements)	7.8	NPD
Voice alarm condition output (option with requirements)	7.9	PASS
Fault Warning Conditions	8.	PASS
Disabled Condition	9.	PASS
Voice Alarm Manual Control	10.	PASS
Interface to External Control Device(s)	11.	PASS
Emergency Microphone(s)	12.	PASS
Design Requirements	13.	PASS
Additional Design Requirements for Software Controlled VACIE	14.	PASS
Output Power	16.4	PASS
Signal-to-noise Ratio	16.5	PASS
Frequency Response of VACIE Without Microphone(s)	16.6	PASS
Frequency Response of VACIE With Microphone(s)	16.7	PASS
Cold (Operational)	16.8	PASS
Damp, Heat, Steady State (Operational)	16.9	PASS
Damp, Heat, Steady State (Endurance)	16.10	PASS
Impact (Operational)	16.11	PASS
Vibration, Sinusoidal (Operational)	16.12	PASS
Vibration, Sinusoidal (Endurance)	16.13	PASS
Supply Voltage Variation (Operational)	16.14	PASS
Electromagnetic Compatibility (EMC), Immunity tests (Operational)	16.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

LGAI Technological Center, S.A. (APPLUS)
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona)
T +34 93 567 20 00
CIF: A-63207492
www.appluslaboratories.com



Technical Annex Ed. 5 06/05/2022

0370-CPR-3261

Other technical data			
NEO8060			
Voltage	110-120 / 220-240 V		
Frequency	50-60 Hz		
AC Power Consumption	550 W		
Analog audio inputs	5		
Line finisher TFL-1 and TFL-2	End of line devices for speaker lines		
ETX module	Communications card		
Voice Alarm Panels VAP1	Up to 8 remote devices in NEO ACSI bus		
Multipaging Microphones MPS-8Z	Up to 8 remote devices in NEO ACSI bus		
+ NEO8250E			
AC Power Consumption	900 W		
Power amplifier Channels	8 amplifiers class D of 250 W per channel at 100V/70V		
+ NEO4250E			
AC Power Consumption	900 W		
Power amplifier Channels	4 amplifiers class D of 500 W per channel (maximum 1000W in total) at 100V/70V		
	+ NEO4500E		
AC Power Consumption	900 W		
Power amplifier Channels	4 amplifiers class D of 1000 W per channel (maximum 2000W in total) at 100V/70V		
+ NEO4500LE			
AC Power Consumption	900 W		
Power amplifier Channels	4 amplifiers class D of 500 W per channel at 4 ohms (low impedance)		

All Essential requirements and Implemented Options described in this certificate have been determined in combination of the NEO8250E, NEO4250E, NEO4500E and NEO4500LE equipment with the NEO8060 base equipment.