

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No. **0370-CPR-3906**

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS. COMPONENTS OF VOICE ALARM SYSTEMS. LOUDSPEAKERS
MODEL: **DS-60TN (LDADS60TNS02)**

Placed on the market under the name of:

LDA audioTech S.L.

C/ SEVERO OCHOA, 31 – PARQUE TECNOLÓGICO ANDALUCÍA
25590 MÁLAGA (SPAIN)

And produced in the manufacturing plant:

23/32305262

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-24:2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 10th July 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 15th September 2023.

The monitoring assessment will be done before 31st July 2024

Bellaterra, 15th September 2023



 LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

0370-CPR-3906

Annex according to **EN 54-24:2008**

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 24: COMPONENTS OF VOICE ALARM SYSTEMS. LOUDSPEAKERS

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Frequency response limits	4.2	PASS
Durability	4.3	PASS
Construction	4.4	PASS
Marking and data	4.5	PASS
Reproducibility	5.2	PASS
Rated impedance	5.3	PASS
Horizontal and vertical coverage angles	5.4	PASS
Maximum sound pressure level	5.5	PASS
Rated noise power (durability)	5.6	PASS
Dry heat (operational)	5.7	PASS
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	PASS
Damp heat, cyclic (operational)	5.10	PASS
Damp heat, steady state (endurance)	5.11	PASS
Damp heat, cyclic (endurance)	5.12	NA
Sulfur dioxide (SO ₂) corrosion (endurance)	5.13	PASS
Shock (operational)	5.14	PASS
Impact (operational)	5.15	PASS
Vibration, sinusoidal (operational)	5.16	PASS
Vibration, sinusoidal (endurance)	5.17	PASS
Enclosure protection	5.18	PASS

PASS; NPD = No Performance Determined; NA = Not Applicable