

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00676

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Coaxial Ceiling Loudspeaker

Placed on the market under the name or trade mark of: (refer to attached appendix for details and conditions)
LDA AUDIO TECH (LDA AUDIO Y VIDEO PROFESIONAL S.L.)
Parque Tecnológico Andalucía, C/Severo Ochoa 31
29590 Malaga, Spain

and produced in the manufacturing plant(s): ---
Life Safety A/V (Guangzhou) Co., Ltd. (SG- 15578)
No. 257 (Building 3, Floors 1-2) Jun Ye Road
Guangzhou GETDD East, 510530, P. R. China

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-24:2008


Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00676** on **2018-04-11** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body
0905

Certification Manager: Dipl.-Ing. Roland Heine **Date Issue:** 2019-10-15

Signature:





Issue: 1

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00676

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00676

The details and conditions of use for the Coaxial Ceiling Loudspeaker, placed on the market under the name or trade mark of:

LDA AUDIO TECH (LDA AUDIO Y VIDEO PROFESIONAL S.L.)

Parque Tecnológico Andalucía, C/Severo Ochoa 31, 29590 Malaga, Spain

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-24: 2008:

Model	Manufacturing Location	Description
LDASC95TNS01	SG- 15578	24W, Coaxial Ceiling Loudspeaker

Conditions of use:

Suitable for indoor (Type A) applications

Approved settings:

The following line voltage and power tap settings have been approved:-

LDASC95TNS01	
Line Voltage	Power Tap
70 V	12 W, 6 W, 3 W, 1.5 W
100 V	24 W, 12 W, 6 W, 3 W

The following impedance (transformer bypass) setting has been approved:-

LDASC95TNS01	
Impedance	
	4 Ω

General Notes:

1. Evaluated under Intertek project number G103401128.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.