

DECLARATION OF PERFORMANCE



According to Construction Products Regulation EU N° 305/2011

003 CPR 2023

1 Unique Product identification code:

LDAVTX15TNS01

2 Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

LDAVTX15TNS01

3 Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire safety. Loudspeakers for voice alarm system for fire detection and fire alarm systems for buildings

4 Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

**LDA Audiotech S.L.
The 5TH Industry Zone Xiamao, Baiyun District, Guangzhou City, Guandong, China.**

5 Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

**LDA Audiotech S.L.
31th Severo Ochoa St. 29590 Málaga – Spain
Telephone: +34 952 028 805
Fax: +34 952 020 598
Web: www.lda-audiotech.com**

6 System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7 In case of the declaration of performance concerning a construction product covered by the harmonized standard:

LGAI TECHNOLOGICAL CENTER S.A.U. Accreditation 0370

performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the following Declaration of Constancy of Performance dated June 30, 2023

0370 CPR 6611

8 In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9 Declared performance

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonised technical specification	
Performance under fire condition	Pass	Clauses: 4.2, 5.2, 5.3, 5.4, 5.5	EN54-24:2008 ^a
Operational reliability	Pass	Clauses: 4.3, 4.4, 4.5, 5.6, 5.18	EN54-24:2008 ^b
Durability of operational reliability: Temperature resistance	Pass	Clauses: 5.7, 5.8, 5.9	EN54-24:2008 ^b
Durability of operational reliability: Humidity resistance	Pass	Clauses: 5.10, 5.11, 5.12	EN54-24:2008 ^b
Durability of operational reliability: Corrosion resistance	Pass	Clauses: 5.13	EN54-24:2008
Durability of operational reliability: Impact and vibration resistance	Pass	Clauses: 5.14, 5.15, 5.16, 5.17	EN54-24:2008

a The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

b For Clauses 5.7, 5.9, 5.10 and 5.18, Type B conditioning was applied.

10 The performance of the product identified in points 1 & 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Name: J. Ayas
Position: Technical Director

Málaga, June 30, 2023

DECLARACIÓN DE PRESTACIONES



Conforme a la Regulación de Productos de Construcción UE Nº 305/2011

003 CPR 2023

1 Código de identificación única del producto tipo:

LDAVTX15TNS01

11 Tipo, lote o número de serie o cualquier otro elemento que permita la identificación del producto de construcción como se establece en el Artículo 11(4):

LDAVTX15TNS01

12 Uso o usos previstos del producto de construcción, con arreglo con la especificación técnica armonizada aplicable, tal como lo establece el fabricante:

Seguridad contra incendios. Altavoces para sistemas de alarma por voz de sistemas de detección y alarma de incendios en edificios

13 Nombre, nombre o marca registrados y dirección de contacto del fabricante según lo dispuesto en el Artículo 11 (5):

**LDA Audiotech S.L.
The 5TH Industry Zone Xiamao, Baiyun District, Guangzhou City, Guandong, China.**

14 En su caso, nombre y dirección de contacto del representante autorizado cuyo mandato abarca las tareas especificadas en el Artículo 12 (2):

**LDA Audiotech S.L.
C/ Severo Ochoa 31, 29590 Málaga – España
Teléfono: +34 952 028 805
Fax: +34 952 020 598
Web: www.lda-audiotech.com**

15 Sistema o sistemas de evaluación y verificación de la constancia de las prestaciones del producto de construcción tal como figura en el anexo V:

Sistema 1

16 En caso de declaración de prestaciones relativa a un producto de construcción cubierto por una norma armonizada:

LGAI TECHNOLOGICAL CENTER S.A.U. Acreditación 0370

realizó pruebas de tipo e inspección inicial de la fábrica y del control de producción en fábrica con vigilancia continua, aprobó el control de producción en fábrica bajo el sistema 1 y emitió la siguiente Declaración de Constancia de Prestaciones con fecha 30 de junio de 2023

0370 CPR 6611

17 En caso de declaración de prestaciones relativa a un producto de construcción para el que se ha emitido una evaluación técnica europea:

No aplicable, ver punto 7.

18 Declaración de prestaciones

Todos los requisitos, incluyendo todas las características esenciales y las funciones correspondientes para el uso previsto o usos indicados en el punto 3 anterior se han determinado como se describen en las normativas europeas armonizadas que se indican en la tabla siguiente:

Características esenciales	Prestación	Especificación técnica armonizada	
Comportamiento en condiciones de incendio	Pasa	Cláusulas: 4.2, 5.2, 5.3, 5.4, 5.5	EN54-24:2008 ^a
Fiabilidad de funcionamiento	Pasa	Cláusulas: 4.3, 4.4, 4.5, 5.6, 5.18	EN54-24:2008 ^b
Durabilidad de la fiabilidad funcional: resistencia a la temperatura	Pasa	Cláusulas: 5.7, 5.8, 5.9	EN54-24:2008 ^b
Durabilidad de la fiabilidad funcional: resistencia a la humedad	Pasa	Cláusulas: 5.10, 5.11, 5.12	EN54-24:2008 ^b
Durabilidad de la fiabilidad funcional: resistencia a la corrosión	Pasa	Cláusulas: 5.13	EN54-24:2008
Durabilidad de la fiabilidad funcional: resistencia a las vibraciones	Pasa	Cláusulas: 5.14, 5.15, 5.16, 5.17	EN54-24:2008

a Se supone que los productos cubiertos por esta norma entran en condición de alarma, en caso de incendio, antes de que el fuego alcance unas proporciones que puedan afectar su funcionamiento. Por tanto no es un requisito el funcionamiento cuando se expone al ataque directo del fuego.

b Los apartados 5.7, 5.8, 5.9 y 5.18 se aplican los acondicionamientos para los altavoces de tipo B.

19 Las prestaciones del producto identificado en los puntos 1 y 2 son conformes con las prestaciones declaradas en el punto 9.

La presente declaración de prestaciones se emite bajo la sola responsabilidad del fabricante identificado en el punto 4.

Firmado por y en nombre del fabricante por:



Nombre: J. Ayas
Cargo: Technical Director

Málaga, 30 de junio de 2023