

Warsaw, 18.01.2021

DECLARATION OF CONFORMITY

MPL Energy Sp. z o.o. with headquarters in Zabrze, ul. Handlowa 13 declares that the sealed, maintenance-free lead-acid VRLA batteries MW Power meet the requirements of the following standards:

- **PN-EN 60896-21**: 2007 Stationary lead batteries. Types equipped with valves - Test methods.
- **PN-EN 60896-22**: 2007 Stationary lead batteries. Types equipped with valves - Requirements.
- **PN-EN 61056-1**: 2008 General purpose lead batteries. Types equipped with valves. General requirements, functional characteristics - Test methods.
- **PN-EN 61056-2**: 2003 General standards for lead batteries. Types equipped with valves - size, terminals and marking.
- **PN-E-83016**: 1999 Lead batteries. Cells and portable batteries. Types equipped with valves - Recommendations for safety of use in electrical equipment.
- **PN-EN IEC 62485-2**: 2018 Safety requirements for secondary batteries and battery installation.

Additionally, we declare compliance of MW Power batteries with the following standards:

Directives 2006/66/WE (Dz. U. UE L 266/1/2006)

Directives 2013/56/UE (Dz. U. UE L 329/5/2013)

To the extent that the above-mentioned Directive on batteries made in technology AGM or gel.

At the same time, we inform you that there is no obligation to label above-mentioned CE marked batteries because they are not subject to Directive 2014/35 / EU (LVD) and Directive 2014/30 / EU (EMC).

Sincerely,

A handwritten signature in blue ink, appearing to read 'Paweł Kostrzewa', is written over a blue oval stamp. Below the signature, the text 'Członek Zarządu' is printed in a bold, black font.
Paweł Kostrzewa
Członek Zarządu